



City of New Orleans  
 Department of Public Works  
 Lakeview City Park  
 Proposed Drainage Improvements  
 New Orleans, Louisiana

LOG OF BORING AND TEST RESULTS

**Boring: PS-13**

Project No: 24192  
 Date: 02/05/2021  
 Latitude: 30.01203°  
 Longitude: -90.09162°

Water Depth: See Text  
 Total Depth: 7.0 ft

Scale in Feet	PP	SPT	S P L R	Symbol	Visual Classification	USC	Sample Number	Depth in Feet	Water Content %	Density		Shear Tests			Atterberg Limits			Other Tests
										Dry pcf	Wet pcf	Type	φ	C <sub>psf</sub>	LL	PL	PI	
0					2' Water	Water	NS	0										
0.50					Dark gray organic silty clay w/black humus lenses & layers, & roots	OL	B-1	2	342									
0.50					Gray silty clay w/trace of organic matter	CL	B-2	3	41									
0.50					Gray clay w/light brown organic clay layers & trace of organic matter	CH	B-3	4	97									
5 0.50					Gray silty clay w/dark gray organic clay layers & roots	CL	B-4	5	40									
0.50					Light gray clay w/sand pockets, trace of sand lenses, & roots	CH	B-5	6	31									

EUSTIS GINT LIBRARY062019.GLB EE STANDARD BORING LOG 24192.GPJ 6/23/21

NOTES: All PS Borings were sampled using a hand piston sampler.