

LOG OF BORING AND TEST RESULTS

NEW ORLEANS PUBLIC LIBRARY
 NORMAN MAYER BRANCH LIBRARY
 2098 FOY STREET
 NEW ORLEANS, LOUISIANA



Ground Elev.: Datum: Water Depth: See Text Job No.: 20564 Date Drilled: 3/17/09 Boring: 1 Refer to "Legends & Notes"

Scale In Feet	PP	SPT	S P L R	Symbol	Visual Classification	USC	Sample Number	Depth In Feet	Water Content Percent	Density		Shear Tests			Atterberg Limits			Other Tests
										Dry	Wet	Type	σ	C	LL	PL	PI	
0					Loose tan sand & shells	SP	PB-1	0-0.5										
1.00					Medium stiff brown sandy clay w/shells, gravel, concretions, & glass	CL	2	2-3	24									DIST.
0.50					Medium stiff tan & gray clay w/silt pockets & concretions	CH	3	5-6	39	84	116	UC	--	630				
0.50					w/silt pockets, roots, & concretions	CH	4	8-9	40	83	116	UC	--	548				
10					Soft gray clay w/organic matter	CH	5	11-12	62	63	102	UC	--	391				
0.50					w/organic matter & roots	CH	6	14-15	67	61	101	UC	--	344				
0.25					Very soft gray silty clay w/silty sand layers	CL	7	19-20	42	82	116	UC	--	166				
20					w/roots	CH	8	24-25										
0.50					w/silty sand layers	CH	9	29-30	36	87	119							
30					Medium stiff gray clay	CH	10	34-35										
0.50						CH	11	39-40	56	68	106	UC	--	640				
40					Loose gray fine sand	SP												
0.25					Medium stiff gray sandy clay	CL	PB-12	44-45										
50		16				CL	PB-13	46.5-48										

Comments: Latitude: 29° 59.855' N
 Longitude: 90° 03.689' W

LOG OF BORING AND TEST RESULTS

NEW ORLEANS PUBLIC LIBRARY
 NORMAN MAYER BRANCH LIBRARY
 2098 FOY STREET
 NEW ORLEANS, LOUISIANA



Ground Elev.: Datum: Water Depth: See Text Job No.: 20564 Date Drilled: 3/17/09 Boring: 1 Refer to "Legends & Notes"

Scale In Feet	PP	SPT	S P L R	Symbol	Visual Classification	USC	Sample Number	Depth In Feet	Water Content Percent	Density		Shear Tests			Atterberg Limits			Other Tests	
										Dry	Wet	Type	σ	C	LL	PL	PI		
50					Stiff gray silty clay (fissured)	CL													
	2.00						14	54-55	29	96	123	UC	--	1160					
60					Stiff gray & tan clay w/silt pockets	CH	15	59-60	26	99	125	UC	--	1888					
	2.50																		
	3.50						16	64-65	35	85	115	UC	--	1113					
70					Stiff gray & tan clay														
	2.50				Stiff gray silty clay	CL	17	69-70											
	1.00						18	74-74.5	25	101	126	UC	--	1333					
					Stiff gray sandy clay	CL													
80					Stiff gray clay (fissured)	CH	19	79-80											
	1.75																		
	1.50				Stiff gray sandy clay	CL	20	84-85	42	80	113	UC	--	1628					
90					Medium stiff gray silty clay (No Recovery)	CL	21	89-90											
	1.75																		
					Medium stiff gray clay w/silt layers	CH	PB-22	95-96.5											
100	0.50						23	99-100	36	86	117	UC	--	585					

Comments: Latitude: 29° 59.855' N
 Longitude: 90° 03.689' W