





ELEVATIONS IN FEET - N.G.V.D.



TABULAR TEST DATA

NO.	EL.	TYPE	Φ	C - T ²	CLASS
1	-4.6	0	0.0	0.09	CU
2	-7.6	0	0.0	0.09	CU
3	-10.6	0	0.0	0.09	CU
4	-13.6	0	0.0	0.09	CU
5	-16.6	0	0.0	0.260	CU
6	-19.6	0	0.0	0.365	CU
7	-22.6	0	0.0	0.463	CU
8	-25.6	S	29.1	0.000	SM

- ### NOTES
- - (UC) UNCONFINED COMPRESSION TEST
 - - (U) UNCONSOLIDATED - UNDRAINED TRIAXIAL SHEAR TEST
 - ▲ - (R) CONSOLIDATED - UNDRAINED TRIAXIAL SHEAR TEST
 - - (S) CONSOLIDATED - DRAINED DIRECT SHEAR TEST
 - _{UP} - ○_{UN} - ○_{UL} - ATTERBERG LIMITS
- BORING WAS TAKEN WITH A 3 INCH DIAMETER STEEL TUBE PISTON TYPE SAMPLER. FOR SOIL BORING LEGEND SEE PLATE A. FOR LOCATION OF BORINGS SEE PLATE FOR DETAILED TEST DATA SEE



 SOLE AGENT FOR THE PROJECT
 U.S. ARMY ENGINEER DISTRICT, NEW ORLEANS
 CORPS OF ENGINEERS
 NEW ORLEANS, LOUISIANA
 UPTOWN SUBBASIN
 ORLEANS PARISH, LOUISIANA
 UNDISTURBED BORING
 BORING J14

DESIGNED BY: VANOVICH
 DRAWN BY: MOORE
 CHECKED BY: VANOVICH
 DATE: JUNE 2002

PROJECT SCALE: PLOT DATE: 02/11/02
 SHEET NO.: 11-4-45111