



Ground Elev.:		Datum:		Gr. Water Depth: See Text		Job No.: 20901		Date Drilled: 2/22/10		Boring: A-2		Refer to "Legends & Notes"					
Scale In Feet	PP	SPT	S P L R	Symbol	Visual Classification	USC	Sample Number	Depth In Feet	Water Content Percent	Density		Shear Tests		Atterberg Limits			Other Tests
										Dry	Wet	Type	ø	C	LL	PL	
0							1	0-0.5									
	1.00				Loose black silty sand (fill) w/gravel	SM	2	1-2	47								
	1.00				Medium stiff gray & brown clay w/silty sand pockets & roots	CH	3	3-4									
	1.00				Soft gray clay w/silt pockets	CH	4	5-6	60								
					Wood	WD	5	7-8									
	0.75				Soft gray clay w/roots	CH	6	9-10	74								
	0.50				Soft dark gray humus w/wood	Pt	7	11-12									
	0.50						8	13-14									
	0.50				Very soft gray clay w/silt pockets & roots	CH	9	15-16	59								
	0.50						10	17-18									
	0.50						11	19-20									

Comments: Latitude: 29° 58.203' N
Longitude: 90° 02.077' W