EUSTIS ENGINEERING COMPANY, INC.

LOG OF BORING AND TEST RESULTS ANDREW P. SANCHEZ (COPELIN-BYRD) COMMUNITY CENTER NORTH ROMAN STREET NEW ORLEANS, LOUISIANA

(Sheet 1 of 1)



Ground Elev.:		Datum:		Gr. Water Depth: Se	e Text	Job No.	: 20885	Date Drilled: 1/2			)/10 <b>B</b> c			oring: A-4			Refer to "Legends & Notes"	
Scale	PP	SPT	S P L Symbol	Visual Classification	USC	Sample Number	Depth In Feet	Water Content Percent	Density		Shear Tests			Atterberg Limits				Other
In Feet									Dry	Wet	Туре	ø	С	LL	PL	. PI		Tests
0 -				Shells w/silty sand Medium stiff gray & tan clay w/shells & roots w/silt pockets, roots, & wood Medium stiff gray & tan clay	SI	1 2 3 4	0-0.5 1-2 3-4 5-6	7 53										
10 —				Very soft gray clay w/wood, roots, & organic matter w/wood	CH	5 6	7-8 9-10	128										
20 —																		
30 —																		
40 —																		·
50					AND A CONTRACTOR OF THE PARTY O													

Comments: Latitude: 29° 58.087' N

Longitude: 90° 00.881' W