

FCBR\_LOG (FINAL)\_04.57124029.GPJ\_FUGRO DATA TEMPLATE 042610.GDT 01/31/14

DEPTH, FT	WATER LEVEL	SYMBOL SAMPLES	BLOWS PER FOOT	LOCATION: Lake Terrace Drive COORDINATES: N 30° 01' 47.74" W 90° 04' 45.71" SURFACE EL.: Not Available	STRATUM DEPTH, FT	CLASSIFICATION					SHEAR STRENGTH							
						UNIT DRY WT, PCF	PASSING NO. 200 SIEVE, %	WATER CONTENT, %	LIQUID LIMIT	PLASTIC LIMIT	PLASTICITY INDEX (PI)	KIPS PER SQ FT						
				STRATUM DESCRIPTION														
				CONCRETE, 5.9-inches														
1				FAT CLAY (CH), firm, light gray	0.5													
2				- stiff with sand below 2'														
3																		
4									58	15	43							
5				POORLY GRADED SAND WITH CLAY (SP-SC), light gray	4.5		21	31										
5.5					5.5													
6																		
7																		
8																		
9																		

**NOTES:**

- Terms and symbols defined on Plates A-12a and A-12b.

COMPLETION DATE: September 16, 2013  
 TOTAL DEPTH: 5.5'  
 CAVED DEPTH: Not Applicable  
 DRY AUGER: 0' to 5.5'  
 WET ROTARY: Not Applicable  
 BACKFILL: Sand/ Cold Patch Asphalt  
 LOGGER: By Contractor



Fugro Consultants, Inc.

Lake Terrace and Lake Oaks Street Improvements FEMA

**LOG OF BORING NO. LTO-05**

New Orleans, Louisiana

Project No.

04.57124029

PLATE A-5