

FCBR\_LOG (INPUT IN INCHES) 04.57124026.GPJ FUGRO DATA TEMPLATE 042610.GDT 07/03/13

DEPTH, FT	WATER LEVEL	SYMBOL SAMPLES	BLOWS PER FOOT	LOCATION: See Plate 1 COORDINATES: N 29° 58' 47.6" W 90° 02' 41.7" SURFACE EL.: Not Available	STRATUM DEPTH, FT	CLASSIFICATION					SHEAR STRENGTH								
						UNIT DRY WT, PCF	PASSING NO. 200 SIEVE, %	WATER CONTENT, %	LIQUID LIMIT	PLASTIC LIMIT	PLASTICITY INDEX (PI)	KIPS PER SQ FT							
				STRATUM DESCRIPTION															
				<b>ASPHALT</b> , 7-inches															
1				<b>FILL: BASE COURSE</b> , 8-inches - Sand and shells, gray	0.6														
2				<b>FAT CLAY (CH)</b> , firm, greenish gray, with organics and shell fragments	1.3			55	93	33	60								
2.7				- with wood below 2.7'															
4.1				- soft, brown and gray below 4.1'															
4.8								62	63										
4.8								48	90										
5.5					5.5														

**NOTES:**

- Terms and symbols defined on Plates A-11a and A-11b.
- Water was not encountered during the dry auger drilling interval.

COMPLETION DATE: February 8, 2013  
 TOTAL DEPTH: 5.5'  
 CAVED DEPTH: Not Applicable  
 DRY AUGER: 0' to 5.5'  
 WET ROTARY: Not Applicable  
 BACKFILL: Sand/Cold Patch Asphalt  
 LOGGER: C. Brewer



Fugro Consultants, Inc.

St. Claude Paving Only FEMA

**LOG OF BORING NO. B-46A**

New Orleans, Louisiana

Project No.

04.57124026

PLATE A-6