

FCBR\_LOG (INPUT IN INCHES) 57124026.GPJ FUGRO DATA TEMPLATE 042610.GDT 07/01/13

DEPTH, FT	WATER LEVEL	SYMBOL SAMPLES	BLOWS PER FOOT	LOCATION: See Plate 1 COORDINATES: N 29° 57' 52.2" W 90° 02' 24.7" SURFACE EL.: Not Available	STRATUM DEPTH, FT	CLASSIFICATION					SHEAR STRENGTH							
						UNIT DRY WT, PCF	PASSING NO. 200 SIEVE, %	WATER CONTENT, %	LIQUID LIMIT	PLASTIC LIMIT	PLASTICITY INDEX (PI)	KIPS PER SQ FT						
				STRATUM DESCRIPTION														
				<b>ASPHALT</b> , 7-inches														
1				<b>FILL: BASE COURSE</b> , 8-inches - Brick fragments and shells	0.6													
				<b>FILL:</b> Clay, dark gray, with shells and brick fragments	1.3													
2				<b>LEAN CLAY (CL)</b> , stiff, gray and tan, with ferrous nodules and organic  - soft, tan below 2.7'	2.0	93	27											
3					84	36												
4						36	35	24	11									
5						37	40	24	16									
					5.5													

**NOTES:**

- Terms and symbols defined on Plates A-11a and A-11b.
- Water was not encountered during the dry auger drilling interval.

COMPLETION DATE: February 6, 2013  
 TOTAL DEPTH: 5.5'  
 CAVED DEPTH: Not Applicable  
 DRY AUGER: 0' to 5.5'  
 WET ROTARY: Not Applicable  
 BACKFILL: Sand/Cold Patch Asphalt  
 LOGGER: C. Brewer



Fugro Consultants, Inc.

St. Claude Paving Only FEMA

**LOG OF BORING NO. B-12**

New Orleans, Louisiana

Project No.

04.57124026

PLATE A-5