





BORING LOG

BORING NO.: POA-4
PROJECT: Plum Orchard Street Rehabilitation
PROJECT LOCATION: New Orleans LA
BORING LOCATION: N554204.35 E3703833.1
DATE DRILLED: 01/27/2013
WATER LEVEL: Not Encountered
GEOL/ENGR: SE/SA

PROJECT NO.: ASP-1304-G016
METHOD: AUGER
BORING ELEVATION: Not Surveyed
DATE COMPLETED: 01/27/2013
WATER LEVEL DATE: 01/27/2013
DRILLER: VG

DEPTH (FEET)	SAMPLE	Qu (TSF)	Moisture Content (%)	Dry Unit Weight (PCF)	LL	PI	Symbol	MATERIAL CLASSIFICATION
								3 Inches of Asphalt
								8 Inches of Base Material
		0.42	77	56	118	70		Soft Gray Elastic Silt (MH) with Organics
5			74		79	44		Gray Fat Clay (CH) with Organics
			46					-with silt
10								
15								
20								

COMMENTS:

 Rock Core  Shelby Tube

Grant Street

APS Design and Testing, LLC