



City of New Orleans
 Tulane-Gravier and Iberville Neighborhoods
 Sewerage and Water Board Repairs
 Orleans Parish, Louisiana
 Project No: 22241

LOG OF BORING AND TEST RESULTS

B-2

Latitude: 29.95915
 Longitude: -90.09160

Water Depth: See Text
 Total Depth: 5.0 ft

EUSTIS ENGINEERING

Date: 10/3/2013

Scale in Feet	PP	SPT	S P L R	Symbol	Visual Classification	USC	Sample Number	Depth in Feet	Water Content Percent	Density		Shear Tests			Atterberg Limits			Other Tests
										Dry	Wet	Type	ϕ	C	LL	PL	PI	
0					6" Asphalt													
		3			Black crushed asphalt w/silty clay pockets			0.6	29									
		4			Loose black clayey sand w/gravel & trace of shell fragments	SC		2.5	16									
					Soft gray clay w/roots	CH		4	67					106	31	75		
5																		
10																		
15																		
20																		
25																		

NOTES:

EUSTIS GINT LIBRARY04102013.GLB EE STANDARD BORING LOG - 22241.GPJ EE STANDARD DATATEMPLATE.GDT 11/22/13