



City of New Orleans  
 Tulane-Gravier and Iberville Neighborhoods  
 Sewerage and Water Board Repairs  
 Orleans Parish, Louisiana  
 Project No: 22241

LOG OF BORING AND TEST RESULTS

B-3

Latitude: 29.96092  
 Longitude: -90.08747

Water Depth: See Text  
 Total Depth: 5.0 ft

EUSTIS ENGINEERING

Date: 10/7/2013

Scale in Feet	PP	SPT	SPT R	Symbol	Visual Classification	USC	Sample Number	Depth in Feet	Water Content Percent	Density		Shear Tests			Atterberg Limits			Other Tests
										Dry	Wet	Type	$\phi$	C	LL	PL	PI	
0					8" Concrete													
		5			Medium compact brown clayey silt w/gravel & trace of shell fragments	ML	1	0.8	22									
		4			Loose gray crushed concrete w/clayey sand pockets	GP-GC	2	2										#200 = 7.2%
		5			Loose gray silty sand w/gravel	SM	3	3.5	14									
5																		
10																		
15																		
20																		
25																		

NOTES:

EUSTIS GINT LIBRARY04102013.GLB EE STANDARD BORING LOG 22241.GPJ EE STANDARD DATA TEMPLATE.GDT 11/22/13