



City of New Orleans
 Pavement Investigation
 Dillard Neighborhood
 Orleans Parish, Louisiana
 Project No: 22243

LOG OF BORING AND TEST RESULTS

B-4

Latitude: 30.00133
 Longitude: -90.06733

EUSTIS ENGINEERING

Date: 10/2/2013

Water Depth: See Text
 Total Depth: 5.0 ft

Scale in Feet	PP	SPT	S P L R	Symbol	Visual Classification	USC	Sample Number	Depth in Feet	Water Content Percent	Density		Shear Tests			Atterberg Limits			Other Tests
										Dry	Wet	Type	ϕ	C	LL	PL	PI	
0					7" Concrete		NS	0										
		3			Soft gray silty clay w/gravel & shell fragments	CL	1	0.58	47									
					Soft gray clay w/gravel, shell fragments, fine sand pockets, & concretions	CH	2	2	15					93	18	75		
					w/silt pockets & shells		3	4	50									
5																		
10																		
15																		
20																		
25																		

NOTES:

EUSTIS GINT LIBRARY\04102013.GLB EE STANDARD BORING LOG 22243.GPJ EE STANDARD DATATEMPLATE.GDT 12/2/13