



City of New Orleans  
 Pavement Investigation  
 Dillard Neighborhood  
 Orleans Parish, Louisiana  
 Project No: 22243

# LOG OF BORING AND TEST RESULTS

**B-8**

Latitude: 29.99972  
 Longitude: -90.06060

Water Depth: See Text  
 Total Depth: 5.0 ft

EUSTIS ENGINEERING

Date: 10/2/2013

Scale in Feet	PP	SPT	S P L R	Symbol	Visual Classification	USC	Sample Number	Depth in Feet	Water Content Percent	Density		Shear Tests			Atterberg Limits			Other Tests
										Dry	Wet	Type	$\phi$	C	LL	PL	PI	
0					3" Asphalt	GP	NS	0										
		5			Loose gray crushed stone	GP	1	0.25	6									
					Soft gray silty clay	CL	2	2	27					33	20	13		
					Soft tan silty clay	CL	3	4	27									
5																		
10																		
15																		
20																		
25																		

NOTES:

EUSTIS GINT LIBRARY\04102013.GLB EE STANDARD BORING LOG 22243.GPJ EE STANDARD DATATEMPLATE.GDT 12/2/13