



City of New Orleans  
 Pavement Investigation  
 Dillard Neighborhood  
 Orleans Parish, Louisiana  
 Project No: 22243

# LOG OF BORING AND TEST RESULTS

**B-12**

EUSTIS ENGINEERING

Date: 10/2/2013

Latitude: 29.99203  
 Longitude: -90.05999

Water Depth: See Text  
 Total Depth: 5.0 ft

Scale in Feet	PP	SPT	S P L R	Symbol	Visual Classification	USC	Sample Number	Depth in Feet	Water Content Percent	Density		Shear Tests			Atterberg Limits			Other Tests
										Dry	Wet	Type	$\phi$	C	LL	PL	PI	
0					3" Asphalt		NS	0										
					7" Concrete		NS	0.25										
					Stiff gray & tan clay w/silt pockets & trace of organic matter	CH	1	0.83	34									
					Soft gray & tan silty clay w/trace of organic matter	CL	2	2	48					90	27	63		
5	1.00				Stiff gray & tan clay w/silt pockets & trace of organic matter	CH	3	4	50									
10																		
15																		
20																		
25																		

NOTES:

EUSTIS GINT LIBRARY\04102013.GLB EE STANDARD BORING LOG 22243.GPJ EE STANDARD DATATEMPLATE.GDT 12/2/13