

# BORING LOG

**BORING NO.:** R16-P180 TANNER S. DAVIS DR.  
**PROJECT:** READ BLVD. IMPROVEMENTS  
**PROJECT LOCATION:** NEW ORLEANS, LA  
**BORING LOCATION:** SEE BORING LOCATION PLAN  
**BORING ELEVATION:** EXISTING GRADE  
**GEOL/ENGR:** RM  
**METHOD:** AUGER

**PROJECT NO.:** B12-084  
**DATE DRILLED:** 12/05/13  
**DATE COMPLETED:** 12/05/13  
**WATER LEVEL:** 6 ft  
**WATER LEVEL DATE:** 12/05/13  
**LOGGED BY:** WW  
**DRILLER:** DT

DEPTH (feet)	SAMPLE	Standard Penetration (Blows/Ft.)	Unconfined Compressive Strength (tsf)	Moisture Content (%)	Dry Unit Weight (pcf)	LL	PI	Symbol	MATERIAL CLASSIFICATION
	B			15				6" of Concrete	
	X	2b/ft <sup>1/1/1</sup>	(1)	19				Tan Fine SAND with trace silt (SP-SM)	
								Very Loose, Gray Silty SAND with shells (SM)	
5			0.10	49	67			Very Soft, Gray and Black Fat CLAY (CH)	
	▽			32		59	40	-- brown with silt	
10				57				Bottom at 10 Feet	
								(1) % Passing #200 = 31.1%	
15									
20									

**COMMENTS:**

B BAG  
 SHELBY TUBE

X SPLIT SPOON