



City of New Orleans
 St. Bernard Neighborhood, Public Works Damage and
 Sewerage & Water Board Repairs
 Orleans Parish, Louisiana
 Project No: 22242

LOG OF BORING AND TEST RESULTS





B-2

EUSTIS ENGINEERING

Date: 08/15/2013

Latitude: 29.99902
 Longitude: 90.08437

Water Depth: See Text
 Total Depth: 5.0 ft

Scale in Feet	PP	SPT	S P L R	Symbol	Visual Classification	USC	Sample Number	Depth in Feet	Water Content Percent	Density		Shear Tests			Atterberg Limits			Other Tests
										Dry	Wet	Type	ϕ	C	LL	PL	PI	
0					6" Concrete													
					Soft brown silty clay w/fine sand pockets, trace of organic matter, & trace of shell fragments (base course fill)	CL	1	1	41	77	109	UC	-	316				
					Soft gray sandy clay w/sand & trace of roots	CL	2	2	47						51	15	36	
							3	3										
					Loose gray fine sand w/trace of clay pockets	SP	4	4	29									
5																		
10																		

NOTES:

EUSTIS GINT LIBRARY04102013.GLB EE STANDARD BORING LOG 22242.GPJ EE STANDARD DATATEMPLATE.GDT 9/30/13