

BORING LOG

BORING NO.: POC-2

PROJECT: Plum Orchard Street Rehabilitation

PROJECT LOCATION: New Orleans LA

BORING LOCATION: N554644.14 E3704554.15

DATE DRILLED: 01/25/2013

WATER LEVEL: Not Encountered

GEOL/ENGR: SE/SA

PROJECT NO.: ASP-1304-G016





METHOD: AUGER

BORING ELEVATION: Not Surveyed


DATE COMPLETED: 01/25/2013

WATER LEVEL DATE: 01/25/2013

DRILLER: VG

| DEPTH (FEET) | SAMPLE | Qu (TSF) | Moisture Content (%) | Dry Unit Weight (PCF) | LL | PI | Symbol | MATERIAL CLASSIFICATION |
|--------------|--------|----------|----------------------|-----------------------|-----|----|---|-------------------------------------|
| | | | | | | |  | 6 Inches of Concrete |
| | | | 72 | | 112 | 69 |  | Gray Fat Clay (CH) with Organics |
| | | | 55 | | 66 | 38 |  | -with Organics |
| 5 | | 0.19 | 39 | 78 | | |  | -Very Soft; traces of Sand and silt |
| 10 | | | | | | | | |
| 15 | | | | | | | | |
| 20 | | | | | | | | |

COMMENTS:

 Rock Core

 Shelby Tube

Bonita Drive

APS Design and Testing, LLC